


FIGURE 1 - TANK LOCATION ON LOT WITH FRONT AND SIDE RETAINING WALLS

FIGURE 2 - TANK LOCATION ON LOT WITH FRONT BATTER AND SIDE RETAINING WALL

NOTES:

1. WHERE TANK RISERS ARE FITTED, FINISHED LOT LEVELS SHALL BE:
 - 300mm ABOVE CENTRE OF LIFTING POINT FOR 300mm RISERS
 - 600mm ABOVE CENTRE OF LIFTING POINT FOR 600mm RISERS
2. WHERE THERE ARE TWO RETAINING WALLS AT DIFFERENT LEVELS THE LOWER OF THE TWO SHOULD BE REFERENCED.

SIZE A1	DESIGNED:	CK		DRG TITLE: NON STANDARD LOTS - FRONT AND SIDE RETAINING WALLS	NOT TO SCALE	REV
	DRAWN:	SR			DRG No.	0
	CHECKED:	RS			FSI-SK03B-FS	
	0	12/10/16			NEW DRAWING - SK03A AND SK03B REPLACES SK03	NC
	REV	DATE	DESCRIPTION	BY	APPROVED	